

## KIRLOSKAR DIESEL GENERATING SETS



## **KG400W / KG400WS**

Diesel Generating Set Output Ratings					
Model	Prime Rating at 0.8 pf (lag)	Standby Rating at 0.8 pf (lag)	Phase / Hz	Standard Voltage (L-L)	Optional Voltage (L-L)
KG400W (OPEN)	400 kVA	440 kVA	3 Phase /	2901/	2201/
KG400WS (SAE)	320 kW	352 kW	60 Hz	380V	220V

- S
- AE Sound Attenuated Enclosure
- Ratings are according to ISO 8528; refer to ratings definition on page 2.



Note: Above picture shown for illustration purpose only, actual product may be different.

## **Features**

- Extremely reliable.
- Lower operating cost.
- Easy maintenance higher uptime.
- Sound attenuating enclosure (canopy) is fully integrated and designed for all weather conditions (weather proof).
- State of the art generating set control system with high degree of accuracy and reliability.
- V type engine design for lower footprint.
- Extended service interval to 500hrs
- Superior design standards that minimize power deration even at high ambient temperatures.
- Efficient and prompt after sales service available.



# Kinloskar. Enriching Lives

## **Ratings Definition:**

## **Standby Ratings:**

These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings. The alternator on this model is peak continuous rated (as defined in ISO 8528-3)

## **Prime Rating:**

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercial purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

## **Continuous Rating:**

These ratings are applicable for supplying power continuously to a constant load upto the full output rating for unlimited hours. No sustained overload capability is available for this rating.

GENERATING SET SPECIFICATIONS			
Model - Open Type	KG400W		
Model - SAE Type	KG40	KG400WS	
Line Voltage (Volts)	220V 380V		
Phase Voltage (Volts)	Volts) 127V 220V		
Frequency (Hz)	6	60	
Power Factor 0.8		.8	
Phase	Three phase		
Fuel Tank Canacity (Litera)	Open – 530		
Fuel Tank Capacity (Liters)	SAE – 530		
Fuel consumption at 100% load (lit/hr) +5% tolerance	82.5		
Fuel consumption at 75% load (lit/hr) +5% tolerance	63.2		
Sound level at 7 m for Silent Generating set dB(A) 70		0	
Overall dimensions (ama)	Open – 390x190x210		
Overall dimensions (cms)	SAE – 492x200x224		
Woight (kga)	Open Type – 4000		
Weight (kgs)	SAE Type – 6000		

CONTROL SYSTEM		
Controller Make	Deepsea	
Controller Model	DSE 7320 MKII	
Digital display instrumentation	Generator Voltage Generator Amps Generator Frequency Generator kWh Power factor Mains Voltage Battery Voltage Engine hours Run Oil Pressure Gauge Engine Temperature Gauge Fuel Level	
Fail to Stop Low Oil pressure High Engine Temperature Under/Over-speed Under/Over voltage Emergency Stop Failed to reach loading voltage Failed to reach loading frequency Charge Fail Over Current & over kW Low DC Voltage Low coolant level		
Automatic Starting & AMF facility	Available	



## **Engine Technical Data**



Physical Data		
Engine Make	Kirloskar	
Engine Model	DV8	
Cylinders / Configuration	8 / V type	
Туре	Four stroke	
Bore x Stroke (mm)	130 x 150	
Displacement (Ltr)	15.91	
Cooling	Water cooled	
Aspiration	Turbocharged Aftercooled	
Compression Ratio	16.5 : 1	
hp Prime @ 1800rpm	490	
hp Standby @ 1800rpm	539	

Fuel System		
Type of fuel filter	Spin on type	
Governor Type	Electronic	
Class of Governing	ISO 8528-5, Class G2	
Fuel pump type	Inline	
Fuel pump make	Kirloskar	
Recommended Fuel	Class A2, High speed diesel	
Fuel consumption at 100% load (lit/hr) +5% tolerance	82.5	
Fuel consumption at 75% load (lit/hr) +5% tolerance	63.2	
Fuel consumption readings are based on diesel fuel with a specific gravity of 0.85 and confirming to BS 2869, Class A2)		

Air System		
Air Filter Type	Dry type replaceable element	
Air Volume required for Ventilation (m³/hr)	27720	
Combustion air flow (m³/hr)	1980	
Total Air Flow required for ventilation (m³/hr)	27720	
Total Fresh air required (m³/hr)	29700	

Lubrication System		
Type of lube oil filter Full flow spin on typ		
Oil to be used	SAE 15W-40 API : CI4	
Oil pump type	Through G-rotor gear pump	
Lub oil sump capacity (lit)	41	
Lube oil consumption	0.12% of fuel consumption	

Cooling System		
Cooling system capacity (lit)	123	
Water pump type	Centrifugal	
Radiator fan load (hp)	13.6	

Electrical System		
Starting Arrangement	24V Electric	
Starter	24V Electric	
Starter Battery Rating	2 x 180Ah	
Battery charging alternator	Engine mounted 24V battery charger	
Battery charger amps	45	



## **Alternator Technical Data**



**Enriching Lives** 

Phy	ysical Data	
Line Voltage (Volts)	220V	380V
Manufacturer	Stamford	
Model	HCI444F1	HCI444F1
Number of bearings	1	
Insulation class		Н
Winding pitch & Wires	2/3	& 12
Winding connections	Series Delta	Parallel Star
Ingress Protection Rating	IP	23
AVR Model	AS440	

Operating	Data	
Line Voltage (Volts)	220V 380V	
Over speed (RPM)	22	50
Excitation	Self excited	
Efficiency (%)	93.2 93.2	
THD at full linear balanced load AC waveform	<u>&lt;</u> 5	5%
Voltage Regulation (%)	± 1.0	
Reactance per unit (Xd)	2.28 2.28	
Reactance per unit (X'd)	0.15 0.15	
Reactance per unit (X"d)	0.11 0.11	

**General Data** 

Standards

## **Sound Attenuating Enclosure (Canopy)**

Sound Level	70 dB(A) at 7 meter as per ISO 8528
Construction	<ul> <li>Fully Integrated, metal construction for ALL WEATHER USE (weather proof).</li> <li>Black zinc die cast, Aluminium hinges or Stainless steel hinges tested to withstand corrosive environment conditions.</li> <li>Fuel filling spout with lock.</li> <li>Emergency stop button on canopy exterior.</li> <li>Provision of glass window for viewing control panel</li> <li>Provision for lifting canopy</li> </ul>
Maintenance	Easy access through lockable doors for operation/maintenance and repair works (including access for radiator service)
Protection Standard	IP 23

Documents in (soft copies)	Generator user manual
	A full set of Illustrated
	spare parts catalogue
	Operation & Maintenance
	manual
	Circuit Diagrams pasted
	inside control panel
Quality	ISO 8528, ISO 3046, IS
Quality	100002, BS5514, DIN 6271,

ISO 9001, ISO 14001



#### KIRLOSKAR OIL ENGINES LIMITED

**Head Office:** Laxmanrao Kirloskar Road, Khadki, Pune 411 003, India. Tel.: +91 20 2581 0341 / 534 Fax: +91 20 2581 3208 Website: <a href="https://www.koel.co.in">www.koel.co.in</a>

## International business offices **KIRLOSKAR DMCC**

JBC-5, Cluster W, Jumeirah Lake Towers, P.O.Box 37745, Dubai. U.A.E Tel.: +971 4 443 8591 Fax: +971 4 441 4532

Email: enquiry@kirloskar.ae Website: www.kirloskar.ae

## **JOBURG INDUSTRIAL TRADING S.A.(Pty) LTD.**

## KIRLOSKAR KENYA LTD.

#### **KOEL AMERICAS CORPORATION**

33300 Egypt Lane, Suite C300, Magnolia, TEXAS – 77354, United States Office Phone: +1 346 248 5777 Email: Vinay.Kulkarni@koelamerica.com

