




Enriching Lives

KIRLOSKAR DIESEL GENERATING SETS

KG400W / KG400WS

Diesel Generating Set Output Ratings			
Model	Prime Rating at 0.8 pf (lag)	Standby Rating at 0.8 pf (lag)	Phase / Volts / Hz
KG400W (OPEN)	400 kVA 320 kW	440 kVA 352 kW	3 Phase / 415 V / 50 Hz
KG400WS (SAE)			

- SAE – Sound Attenuated Enclosure
- Ratings are according to ISO 8528; refer to ratings definition on page 2.



Note: Above picture shown for illustration purpose only, actual product may be different.

Features

- Extremely reliable.
- Lower operating cost.
- Easy maintenance – higher uptime.
- Sound attenuating enclosure (canopy) is fully integrated and designed for all weather conditions (weather proof).
- Best in class Sound attenuation – 70 dB(A) at 7 meters as per ISO 8528
- State of the art generating set control system with high degree of accuracy and reliability.
- V type engine design for lower footprint.
- Extended service interval to 500hrs
- Superior design standards that minimize power deration even at high ambient temperatures.
- Efficient and prompt after sales service available.
- Winner of the frost & Sullivan Voice of Customer Award in the “Best Bang for Buck” category in the Indian Generating sets Market.

Power, Performance, Peace of Mind.





Enriching Lives

Ratings Definition:

Standby Ratings:

These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings. The alternator on this model is peak continuous rated (as defined in ISO 8528-3)

Prime Rating:

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercial purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

Continuous Rating:

These ratings are applicable for supplying power continuously to a constant load upto the full output rating for unlimited hours. No sustained overload capability is available for this rating.

GENERATING SET SPECIFICATIONS	
Model - Open Type	KG400W
Model - SAE Type	KG400WS
Frequency (Hz)	50
Power Factor	0.8
Phase	Three phase
Line Voltage (Volts)	415
Phase Voltage (Volts)	240
Fuel Tank Capacity (Liters)	Open – 530
	SAE – 530
Fuel consumption at 100% load (lit/hr) +5% tolerance	80.38
Fuel consumption at 75% load (lit/hr) +5% tolerance	61.55
Sound level at 7 m for Silent Generating set dB(A)	70
Overall dimensions (cms)	Open – 400x190x210
	SAE – 492x200x224
Weight (kgs)	Open Type – 4200
	SAE Type – 6000(Approx.)

CONTROL SYSTEM	
Controller Make	Deepsea
Controller Model	DSE 7320 MKII
Digital display instrumentation	Generator Voltage Generator Amps Generator Frequency Generator kWh Power factor Mains Voltage Battery Voltage Engine hours Run Oil Pressure Gauge Engine Temperature Gauge Fuel Level
Shutdowns/Safeties	Fail to Stop Low Oil pressure High Engine Temperature Under/Over-speed Under/Over voltage Emergency Stop Failed to reach loading voltage Failed to reach loading frequency Charge Fail Over Current & over kW Low DC Voltage Low coolant level
Automatic Starting & AMF facility	Available



Power, Performance, Peace of Mind.



Enriching Lives

Engine Technical Data

Physical Data	
Engine Make	Kirloskar
Engine Model	DV8
Number of cylinders	8
Configuration	V type
Type	Four stroke
Bore x Stroke (mm)	130 x 150
Displacement (Ltr)	15.91
Cooling	Water cooled
Aspiration	Turbocharged Aftercooled
Compression Ratio	16.5 : 1
Starting Arrangement	24V Electric

Fuel System	
Type of fuel filter	Spin on type
Governor Type	Electronic
Class of Governing	ISO 3046 Class A1 & ISO 8528-5, Class G2
Fuel pump type	Inline
Fuel pump make	Kirloskar
Recommended Fuel	Class A2, High speed diesel
Fuel consumption at 100% load (lit/hr) +5% tolerance	80.38
Fuel consumption at 75% load (lit/hr) +5% tolerance	61.55
Fuel consumption readings are based on diesel fuel with a specific gravity of 0.85 and confirming to BS 2869, Class A2)	

Air System	
Air Filter Type	Dry type replaceable element
Air Volume required for Ventilation (m ³ /hr)	27720
Combustion air flow (m ³ /hr)	1980
Total Air Flow required for ventilation (m ³ /hr)	27720
Total Fresh air required (m ³ /hr)	29700

Lubrication System	
Type of lube oil filter	Full flow spin on type
Oil to be used	SAE 15W-40 API : CI4
Oil pump type	Through G-rotor gear pump
Lub oil sump capacity (lit)	41
Lube oil consumption	0.3% of fuel consumption

Cooling System	
Cooling system capacity (lit)	123
Water pump type	Centrifugal
Radiator fan load (hp)	13.6

Electrical System	
Starting Arrangement	24V Electric
Starter	24V Electric
Starter Battery Rating	2 x 180AH
Battery charging alternator	Engine mounted 24V battery charger
Battery charger amps	45



Power, Performance, Peace of Mind.

KIRLOSKAR
GREEN
POWER IDEAS



Enriching Lives

Alternator Technical Data

Physical Data	
Manufacturer	Stamford
Model	HCI444F1
Number of bearings	1
Insulation class	H
Winding pitch	2/3
Wires	12
Ingress Protection Rating	IP 23
AVR Model	AS440

Operating Data	
Over speed (RPM)	2250
Excitation	Self excited
Efficiency (%)	93.6
THD at full linear balanced load AC waveform	≤ 5%
Voltage Regulation (%)	± 1.0
Reactance per unit (Xd)	2.28
Reactance per unit (X'd)	0.15
Reactance per unit (X''d)	0.11

Sound Attenuating Enclosure (Canopy)

General Data

Sound Level	70 dB(A) at 7 meter as per ISO 8528
Construction	<ul style="list-style-type: none"> Fully Integrated, metal construction for ALL WEATHER USE (weather proof). Black zinc die cast, Aluminium hinges or Stainless steel hinges tested to withstand corrosive environment conditions. Fuel filling spout with lock. Emergency stop button on canopy exterior. Provision of glass window for viewing control panel Provision for lifting canopy
Maintenance	Easy access through lockable doors for operation/maintenance and repair works (including access for radiator service)
Protection Standard	IP 23 Standard

Documents in (soft copies)	<ul style="list-style-type: none"> Generator user manual A full set of Illustrated spare parts catalogue Operation & Maintenance manual Circuit Diagrams pasted inside control panel
Quality Standards	ISO 8528, ISO 3046, IS 100002, BS5514, DIN 6271, ISO 9001, ISO 14001



Enriching Lives

KIRLOSKAR OIL ENGINES LIMITED

Head Office: Laxmanrao Kirloskar Road, Khadki, Pune 411 003, India.

Tel.: +91 20 2581 0341 / 534 Fax: +91 20 2581 3208 Website : www.koel.co.in



Power, Performance, Peace of Mind.



Enriching Lives

International Business offices

KIRLOSKAR DMCC

JBC-5, Cluster W, Jumeirah Lake Towers, P.O.Box 37745, Dubai. U.A.E
Tel.: +971 4 443 8591 Fax: +971 4 441 4532
Email: enquiry@kirloskar.ae Website : www.kirloskar.ae

JOBURG INDUSTRIAL TRADING S.A.(Pty) LTD.

Unit B1, The Stables Business Park, Cnr of Third Avenue & Second Road, Limbro Park,
Modderfontein, Johannesburg.
Tel.: +27(0) 11 553 6900/6903
Email: kirsons@kirloskar.co.za

KIRLOSKAR KENYA LTD.

P.O. Box 60061, Off Dunga Road, Nairobi, Kenya.
Tel.: +254 20 653 6632 Fax: +254 20 653 3390
Email: rspatil@kirloskar.co.ke

KOEL AMERICAS CORPORATION

Suite 4, Tamina Business Park, 32407 Tamina Road, Magnolia 77354, Texas USA
Tel.: +1 832 675 1595
Email: Vinay.Kulkarni@koelamerica.com

Kirloskar Oil Engines Limited reserved the right to change the design or specifications without notice

IBG/Q/ 046 Rev 00

Power, Performance, Peace of Mind.

