

KIRLOSKAR DIESEL GENERATING SETS



KG500W / KG500WS

| Diesel Generating Set Output Ratings | | | | | |
|--------------------------------------|---------------------------------|--------------------------------------|------------|------------------------------|------------------------------|
| Model | Prime Rating at 0.8 pf (lag) | Standby Rating at 0.8 pf (lag) | Phase / Hz | Standard Voltage (L-L) | Optional Voltage (L-L) |
| KG500W (OPEN) | 500 kVA | 550 kVA | 3 Phase / | 380V | 220V |
| KG500WS (SAE) | 400 kW | 440 kW | 60 Hz | 3000 | 2200 |

• SAE – Sound Attenuated Enclosure

• Ratings are according to ISO 8528; refer to ratings definition on page 2.



Note: Above picture shown for illustration purpose only, actual product may be different.

Features

- Extremely reliable.
- Lower operating cost.
- Easy maintenance higher uptime.
- Sound attenuating enclosure (canopy) is fully integrated and designed for all weather conditions (weather proof).
- State of the art generating set control system with high degree of accuracy and reliability.
- V type engine design for lower footprint.
- Extended service interval to 500hrs
- Superior design standards that minimize power deration even at high ambient temperatures.
- Efficient and prompt after sales service available.



Power, Performance, Peace of Mind.

Ratings Definition:

Standby Ratings:



These ratings are applicable for supplying continuous electrical power (at variable load) in the event of a utility power failure. No overload is permitted on these ratings. The alternator on this model is peak continuous rated (as defined in ISO 8528-3)

Prime Rating:

These ratings are applicable for supplying continuous electrical power (at variable load) in lieu of commercial purchased power. There is no limitation to the annual hours of operation and this model can supply 10% overload power for 1 hour in 12 hours.

Continuous Rating:

These ratings are applicable for supplying power continuously to a constant load upto the full output rating for unlimited hours. No sustained overload capability is available for this rating.

| GENERATING SET SPECIFICATIONS | | CONTROL SYSTEM | | | |
|---|---|----------------|--------------------|---|--|
| Model - Open Type | KG500W | | | | |
| Model - SAE Type | KG500WS | | | | |
| Line Voltage (Volts) | 220V 380V | | | · · · · · · · · · · · · · · · · · · · | |
| Phase Voltage (Volts) | 127V | 220V | | | |
| Frequency (Hz) | 6 | 0 | Controller Make | Deepsea | |
| Power Factor | 0. | .8 | Controller Model | DSE 7320 MKII Generator Voltage | |
| Phase | Three | phase | | Generator Amps | |
| | Open – 665 | | | Generator Frequency Generator kWh Power factor Mains Voltage Battery Voltage Engine hours Run Oil Pressure Gauge Engine Temperature Gauge Fuel Level Fail to Stop Low Oil pressure High Engine Temperature Under/Over-speed | |
| Fuel Tank Capacity (Liters) | SAE – 860 | | Digital display | | |
| Fuel consumption at 100% load (lit/hr) +5% tolerance | 102.3 78.42 75 | | instrumentation | | |
| Fuel consumption at 75% load (lit/hr) +5% tolerance | | | | | |
| Sound level at 7 m for Silent Generating set dB(A) | | | | | |
| Overall dimensions (cms) | Open – 365x185x235 SAE – 521x212x231 | | | | |
| Overall dimensions (cms) | | | | | |
| | Open Type – 5510 SAE Type – 7160(Approx.) | | | Under/Over voltage Emergency Stop | |
| Weight (kgs) | | | Shutdowns/Safeties | Failed to reach loading voltage Failed to reach loading frequency Charge Fail Over Current & over kW | |
| | | | | Low DC Voltage Low coolant level | |



Available

Automatic Starting &

AMF facility

Engine Technical Data

hp Standby @ 1800rpm

| Physical Data | | |
|---------------------------|-----------------------------|--|
| Engine Make | Kirloskar | |
| Engine Model | DV10 | |
| Cylinders / Configuration | 10 / V type | |
| Туре | Four stroke | |
| Bore x Stroke (mm) | 130 x 150 | |
| Displacement (Ltr) | 17.98 | |
| Cooling | Water cooled | |
| Aspiration | Turbocharged Aftercooled | |
| Compression Ratio | 16.5 : 1 | |
| hp Prime @ 1800rpm | 608 | |

669

| Air System | | |
|--|---------------------------------|--|
| Air Filter Type | Dry type replaceable element | |
| Air Volume required for Ventilation (m ³ /hr) | ТВА | |
| Combustion air flow (m³/hr) | ТВА | |
| Total Air Flow required for ventilation (m ³ /hr) | ТВА | |
| Total Fresh air required (m³/hr) | TBA | |

| Cooling System | | |
|-------------------------------|-------------|--|
| Cooling system capacity (lit) | 133 | |
| Water pump type | Centrifugal | |
| Radiator fan load (hp) | 20.4 | |

| Fuel System | | |
|---|--------------------------------|--|
| Type of fuel filter | Spin on type | |
| Governor Type | Electronic | |
| Class of Governing | ISO 8528-5, Class G2 | |
| Fuel pump type | Inline | |
| Fuel pump make | Kirloskar | |
| Recommended Fuel | Class A2, High speed diesel | |
| Fuel consumption at 100% load (lit/hr) +5% tolerance | 102.3 | |
| Fuel consumption at 75% load (lit/hr) +5% tolerance | 78.42 | |
| Fuel consumption readings are based on diesel fuel with a specific gravity of 0.85 and confirming to BS 2869, Class A2) | | |

| Lubrication System | | |
|-----------------------------|------------------------------|--|
| Type of lube oil filter | Full flow spin on type | |
| Oil to be used | SAE 15W-40 API : CI4 | |
| Oil pump type | Through G-rotor gear pump | |
| Lub oil sump capacity (lit) | 45 | |
| Lube oil consumption | 0.12% of fuel consumption | |

| Electrical System | | |
|-----------------------------|---------------------------------------|--|
| Starting Arrangement | 24V Electric | |
| Starter | 24V Electric | |
| Starter Battery Rating | 2 x 180Ah | |
| Battery charging alternator | Engine mounted 24V battery charger | |
| Battery charger amps | 45 | |





Enriching Lives

Alternator Technical Data



Enriching Lives

| Phy | sical Data | |
|------------------------------|--------------|---------------|
| Line Voltage (Volts) | 220V | 380V |
| Manufacturer | Star | nford |
| Model | HCI544D1 | HCI544D1 |
| Number of bearings | 1 | |
| Insulation class | Н | |
| Winding pitch & wires | 2/3 & 12 | |
| Winding connections | Series Delta | Parallel Star |
| Ingress Protection Rating | IP 23 | |
| AVR Model | AS | 440 |

| Operating Data | | | |
|---|---------------|--------|--|
| Line Voltage (Volts) | 220V 380V | | |
| Over speed (RPM) | 22 | 50 | |
| Excitation | Self e | xcited | |
| Efficiency (%) 94.6 94.6 | | 94.6 | |
| THD at full linear balanced load AC waveform | <u><</u> 5 | 5% | |
| Voltage Regulation (%) | ±´ | 1.0 | |
| Reactance per unit (Xd) | 3.51 | 3.51 | |
| Reactance per unit (X'd) | 0.17 | 0.17 | |
| Reactance per unit (X''d) | 0.12 | 0.12 | |

Sound Attenuating Enclosure (Canopy)

| Sound Level | 75 dB(A) at 7 meter as per ISO 8528 | |
|------------------------|---|--|
| Construction | Fully Integrated, metal construction for ALL WEATHER USE (weather proof). Black zinc die cast, Aluminium hinges or Stainless steel hinges tested to withstand corrosive environment conditions. Fuel filling spout with lock. Emergency stop button on canopy exterior. Provision of glass window for viewing control panel Provision for lifting canopy | |
| Maintenance | Easy access through lockable doors for operation/maintenance and repair works (including access for radiator service) | |
| Protection Standard | IP 23 | |

General Data

| | Generator user manual | | |
|----------------------|---|--|--|
| | A full set of Illustrated | | |
| Documents | spare parts catalogue | | |
| in (soft | Operation & | | |
| copies) | Maintenance manual | | |
| | Circuit Diagrams pasted | | |
| | inside control panel | | |
| Quality | ISO 8528, ISO 3046, IS | | |
| Quality Standards | 100002, BS5514, DIN 6271, | | |
| Stanuarus | ISO 9001, ISO 14001 | | |

KIRLOSKAR OIL ENGINES LIMITED

Head Office: Laxmanrao Kirloskar Road, Khadki, Pune 411 003, India. Tel.: +91 20 2581 0341 / 534 Fax: +91 20 2581 3208 Website : <u>www.koel.co.in</u>

inloskar

Enriching Lives

International business offices **KIRLOSKAR DMCC**

JBC-5, Cluster W, Jumeirah Lake Towers, P.O.Box 37745, Dubai. U.A.E Tel.: +971 4 443 8591 Fax: +971 4 441 4532 Email: <u>enquiry@kirloskar.ae</u> Website : <u>www.kirloskar.ae</u>

JOBURG INDUSTRIAL TRADING S.A.(Pty) LTD.

Unit B1, The Stables Business Park, Cnr of Third Avenue & Second Road, Limbro Park, Modderfontein, Johannesburg. Tel.: +27(0) 11 553 6900/6903 <u>Email: kirsons@kirloskar.co.za</u>

KIRLOSKAR KENYA LTD.

P.O. Box 60061, Off Dunga Road, Nairobi, Kenya. Tel.: +254 20 653 6632 Fax: +254 20 653 3390 <u>Email: rspatil@kirloskar.co.ke</u>

KOEL AMERICAS CORPORATION

33300 Egypt Lane, Suite C300, Magnolia, TEXAS – 77354, United States Office Phone: +1 346 248 5777 <u>Email: Vinay.Kulkarni@koelamerica.com</u>



Kirloskar Oil Engines Limited reserved the right to change the design or specifications without notice

Power, Performance, Peace of Mind.